

TF 0800 806 595
P +64 9 273 3727
F +64 9 273 3726
E info@thermakraft.co.nz

11 Turin Place
East Tamaki, Auckland
PO Box 58112
Botany, Auckland 2163

3 December 2020,

Thermakraft Thermaflash on IBS Rigid Rap Membrane

Thermakraft Thermaflash Flashing Tape was used to perform an in-house 180° peel test as per ASTM D3330 on IBS Rigid Rap on the 21st of October 2020. Thermaflash adhered onto the synthetic IBS Rigid Rap membrane and showed good adhesion and compatibility to the synthetic IBS Rigid Rap membrane.

Thermakraft Thermaflash Flashing Tape is a BRANZ appraised product. See BRANZ Appraisal No. 1122 and Thermaflash technical literatures for full details.

Any changes to the IBS Rigid Rap product (membrane or rigid OSB substrate) are to be notified to Thermakraft and samples to be provided for Thermakraft in-house adhesion and compatibility testing. Thermakraft will also notify IBS of any changes to the Thermaflash tape and will perform compatibility testing if changes occur.

William Lin

A handwritten signature in blue ink that reads "William Lin".

Head of Engineering and Inventory